Report Date: 9/14/2022 Report Time: 4:04 PM EDT

Region II Hotline Log Entry Information

Data ID: 1523396

Material Type: Oil Receiver: Budroe

Material / Amount: OIL, MISC: TRANSFORMER (1700 GALLON(S));

Location: Street:

City: NEW YORK CITY

County: NEW YORK (MANHATTAN)

State: NY Latitude: Longitude:

Source of Pollution: CON EDISON

Water Body: NA

 State Or EPA Responded:
 The leak has not been confirmed.

 Initial EPA Action:
 Contacted the RP for additional information.

Status: 2 - Closed

URL:

Associated Action Reports

DataID: 0684085

 Date: 1/23/2014
 Time: 01:35

 Duty Officer/Responder Name: Budroe
 NRC Report #: 1071876
 Hotline Log DataID: 1523396

Action Information

Description: The system instruments monitoring the system which provides oil/coolant to transformers at two separate locations are indicating a drop in pressure which may signify a leak in the feeder line servicing the transformers. No leak has yet been

located but workers continue inspecting the system in search of a potential leak.

Follup-Up:

Person Contacted

Name: Herman Baker
Organization: CON EDISON
Phone #: (212)5806763

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any

applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 1071876

INCIDENT DESCRIPTION

**** THIS IS A POTENTIAL RELEASE ****

*Report taken by: RHP3612 RHP3612 at 01:05 on 23-JAN-14

Incident Type: FIXED
Incident Cause: UNKNOWN

Affected Area:

The incident was discovered on 23-JAN-14 at 00:45 local time.

Affected Medium: NON-RELEASE (N/A)

REPORTING PARTY

Name: TOM ENRIGHT
Organization: CON EDISON
Address: 128 WEST END AVE

NEW YORK, NY 10023

ALTERNATE Phone: (212)5806763

INCIDENT LOCATION

637 WEST 49TH ST County: NEW YORK (MANHATTAN)

City: NEW YORK CITY State: NY ONE OF TWO SUBSTATIONS: SPRINGBROOK 353 TUCKAHOE RD

YONKERS, NY

POTENTIALLY RELEASED MATERIAL(S)

CHRIS Code: OTF Official Material Name: OIL, MISC: TRANSFORMER

Also Known As:

Qty Released: 1700 GALLON(S)

DESCRIPTION OF INCIDENT

CALLER STATED THAT THEIR GAUGES RELAYED THE LOSS OF APPROXIMATELY 1700 GALLONS OF

DIELECTRIC FLUID. THE CALLER STATED THAT THERE IS A POTENTIAL THAT THERE IS A LOSS OF MATERIAL INTO THE ENVIRONMENT BUT UNTIL THE TWO LOCATIONS CAN BE CHECKED IT IS NOT CERTAIN.

INCIDENT DETAILS

Package: NO

Building ID: SUB STTN.
Type of Fixed Object: OTHER
Power Generating Facility: NO

Generating Capacity:

Type of Fuel:

NPDES:

NPDES Compliance: UNKNOWN

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN

INJURIES: NO Hospitalized: Empl/Crew: Passenger: FATALITIES: NO Empl/Crew: Passenger: Occupant:

EVACUATIONS: NO Who Evacuated: Radius/Area:

Damages: NO

Hours Direction of

Closure Type Description of Closure Closed Closure

Air: N

Road: N Major Art

Waterway: N

Track: N

Passengers Transferred: NO Environmental Impact: UNKNOWN

Media Interest: UNKNOWN Community Impact due to Material:

REPORTING PARTY

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: TOM ENRIGHT Organization: CON EDISON

Address: 128 WEST END AVE

NEW YORK, NY 10023

ALTERNATE Phone: (212)5806763

Type of Organization: PUBLIC UTILITY

REMEDIAL ACTIONS

UNDER INVESTIGATION.

Release Secured: UNKNOWN

Release Rate: 1000 GALLON(S) per HOUR

Estimated Release Duration:

WEATHER

Weather: UNKNOWN, �F

ADDITIONAL AGENCIES NOTIFIED

Federal:

State/Local:

State/Local On Scene: State Agency Number:

NOTIFICATIONS BY NRC

DHS PROTECTIVE SECURITY ADVISOR (PSA DESK)

23-JAN-14 01:11 (703)2355724

DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)

23-JAN-14 01:11 (202)3661863

U.S. EPA II (MAIN OFFICE)

(732) 3214370

NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)

23-JAN-14 01:11 (202)2829201

NJ OFC HMLND SECURITY & PREPAREDNES (COMMAND CENTER)

23-JAN-14 01:11 (609)9636817 NJ STATE POLICE (MARINE SERVICES BUREAU) 23-JAN-14 01:11 (609)9636900

NOAA RPTS FOR NY (MAIN OFFICE)

23-JAN-14 01:11 (206) 5264911 NATIONAL RESPONSE CENTER HQ (AUTOMATIC REPORTS) 23-JAN-14 01:11 (202)2671136 BUREAU TOXIC SUBSTANCE (MAIN OFFICE) 23-JAN-14 01:11 (518)4027810 NY STATE DEC SPILL HOTLINE (MAIN OFFICE) 23-JAN-14 01:11 (518)4577362

NJ DEP POC: DUTY OFFICER (MAIN OFFICE)

23-JAN-14 01:11 (609)5844551 USCG DISTRICT 1 (COMMAND CENTER)

23-JAN-14 01:11 (617)2238555

ADDITIONAL INFORMATION

CALLER STATED THAT THERE IS ONLY READINGS OF A RELEASE OF MATERIAL.

1071876 *** *** END INCIDENT REPORT #

Report any problems or Fax number changes by calling 1-800-424-8802

PLEASE VISIT OUR WEB SITE AT http://www.nrc.uscg.mil